

# METER PEDESTAL/RACK SPECS (DUAL)

- \* MAIN DISCONNECT MUST BE WITHIN ONE FOOT OF THE METER BASE.
- \* MUST HAVE PULL STRING INSIDE PVC PRIOR TO FINAL INSPECTION.
- \* METER BASE MUST BE GROUNDED
- \* IF THE NIPPLE CONNECTING THE METER BASE TO THE EXTERNAL DISCONNECT IS PVC METER BASE MUST BE GROUNDED SEPARATELY. IF THE NIPPLE IS METAL THERE IS NO NEED FOR ADDITIONAL GROUNDING.

