

UNDER GROUND SERVICE SPECS

- * MUST HAVE STRING INSTALLED IN PVC PRIOR TO FINAL INSPECTION.
- * EXTERNAL DISCONNECT MUST BE WITHIN ONE FOOT OF THE METER BASE.
- * MOUNT METER BASE 5'-6' FROM THE GROUND.
- * IF THE NIPPLE CONNECTING THE METER BASE TO THE DISCONNECT IS PVC THE METER BASE MUST BE GROUNDED SEPARATELY. IF THE NIPPLE IS METAL THERE IS NO NEED FOR ADDITIONAL GROUNDING.

