

UNDER GROUND SERVICE SPECS

EXTERNAL DISCONNECT MUST BE WITHIN ONE FOOT OF THE METER BASE.

MOUNT METER BASE 5'-6' FROM GROUND

