

# METER PEDESTAL/RACK SPECS

- \* MAIN DISCONNECT MUST BE WITHIN ONE FOOT OF THE METER BASE.
- \* METER BASE MUST BE GROUNDED
- \* IF NIPPLE IS PVC, METER BASE MUST BE GROUNDED SEPARATE. IF THE NIPPLE IS METAL NO NEED FOR ADDITIONAL GROUNDING.

